

A P P R O V A L S ®

## Certificate of Suitability

## **Certificate No.:**

## SAA160334

Certificate Holder:

Class Description: Product Description:

> Brand Name: Model No.:

> > Markings:

Standard:

Conditions:

**Certification Mark:** 

Date of Expiry:

**Date First Registered:** 

Victron Energy B.V. De Paal 35, 135IJG Almere Netherlands

Non-Declared Bi-directional AC/DC Converter for use in a battery storage system Victron Multiplus 12/3000/120-16

Input:-AC: 187-250V~ 45-55Hz 16A DC: 9.5-17Vdc 250A

Output:-AC: 225-235V~ 50Hz 11A DC: 13.2-14.1Vdc 120A Ta=50°C, Class I

IEC 62109-1 Ed. 1.0 Nil

SAA160334 or RCM

24 May 2016 24 May 2021

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to: www.saaapprovals.com.au





Issued: 24-05-16 160334/1

www.jas-anz.org/register